



SHEET NOTES

- 1 PROVIDE 300V. STARTER SWITCH FOR AIR-EXHAUST DUCTWORK. PROVIDE CONNECTION AND SWITCH FOR UNDER CABINET LIGHT.
- 2 CONDUIT UNDER FLOOR LINE OCCASIONALLY CHANNEL PER SASSWELL INTERNATIONAL DETAILS. PROVIDE CONNECTION TO DRIVE UNIT AS REQUIRED.
- 3 PROVIDE 30A. 3P NEMA 3P DISCONNECT SWITCH WITH STAMP FUSES.
- 4 PROVIDE CONNECTION TO BULLET TRAP VIBRATORS AS INSTRUCTED BY EQUIPMENT MANUFACTURER.
- 5 PROVIDE 300V. OUTLET OF TYPE AS DIRECTED BY OWNER.
- 6 SECURITY SYSTEM J-BOX WITH STUD OUT FOR CODE CONTACTS AND CONDUIT BACK TO SECURITY TERMINAL CABINET PER SECURITY SYSTEM DRAWINGS.
- 7 1" C. EN FOR POWER & TELE/DATA. SAW-CUT SLAB. INSTALL CONDUITS, PATCH & REPAIR SLAB TO MATCH EXIST.
- 8 SURFACE MOUNTED OUTLET BOXES FOR POWER & TELE/DATA. COORDINATE EXACT LOCATION & REQUIREMENTS WITH ARCHITECT.
- 9 PROVIDE 1P J-BOX OR RECEPTACLE AS SHOWN AT MECH. UNIT. PROVIDE CONN. TO MECH. CONTROL PANEL. VERIFY EXACT LOCATION AND REQUIREMENTS WITH MECH. DRINGS.
- 10 PROVIDE CONNECTION TO MECH. CONTROL PANEL AS REQ'D. VERIFY LOCATION WITH MECH. DRINGS.

REVISIONS	BY

GARY B. BAKER ARCHITECT.
 3435 MIWA WYVA RD., SUITE 2410 SAN DIEGO, CA 92116 (619) 584-1000

ACCURACY GUN
 7818 Wilkerson Ct. San Diego, CA 92123

DRAWING CONTENTS	POWER and TELEPHONE PLAN
PROJECT	
DESIGN DEVELOP	1 4-16-94
PLAN CHECK	2 4-22-94
BIDDING	
CONSTRUCTION	
CLARIFICATION	
RECORD	
DATE	4-22-94
SCALE	1/8"=1'-0"
DRAWN	NJP
JOB	3083
ENGR	
F.3	
OF 28 SHEETS	



ILA ENGINEERING
 47 Rufus Road, Suite 2, San Diego, CA 92108-1075
 Ph. (619) 592-0122 Fax (619) 592-0124

LEGEND

POWER & TELE PLAN

1/8" = 1'-0"